



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0C0646

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Watertown H.S.

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 03/06/2020
 Reported: 03/30/2020

Analytical Testing Parameters

Client Sample ID:	51	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/04/2020 6:23
Lab Sample ID:	J0C0646-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0253	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1108	LLW

Client Sample ID:	56	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/04/2020 6:24
Lab Sample ID:	J0C0646-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0053	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1119	LLW

Client Sample ID:	49	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/04/2020 6:20
Lab Sample ID:	J0C0646-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1123	LLW

Client Sample ID:	55	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/04/2020 6:21
Lab Sample ID:	J0C0646-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0162	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1126	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-05		Collection Date: 03/04/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0075	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1130	LLW

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-06		Collection Date: 03/04/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0072	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1134	LLW

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-07		Collection Date: 03/04/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0376	0.015 AL	0.0010	mg/L		03/18/20 1415	03/20/20 0947	LLW

Client Sample ID: 60	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-08		Collection Date: 03/04/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0028	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1145	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 59	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-09		Collection Date: 03/04/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0051	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1149	LLW

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-10		Collection Date: 03/04/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0049	0.015 AL	0.0010	mg/L		03/18/20 1415	03/20/20 0951	LLW

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-11		Collection Date: 03/04/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1152	LLW

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-12		Collection Date: 03/04/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0044	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1156	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-13		Collection Date: 03/04/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0423	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1200	LLW

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-14		Collection Date: 03/04/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0024	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1207	LLW

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-15		Collection Date: 03/04/2020 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0267	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1211	LLW

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-16		Collection Date: 03/04/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.264	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1215	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-17		Collection Date: 03/04/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0217	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1218	LLW

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-18		Collection Date: 03/04/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0170	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1229	LLW

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-19		Collection Date: 03/04/2020 6:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0061	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1233	LLW

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-20		Collection Date: 03/04/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0112	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1237	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 89	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-21		Collection Date: 03/04/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.162	0.015 AL	0.0010	mg/L		03/20/20 1428	03/23/20 1330	DLO

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-22		Collection Date: 03/04/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1241	LLW

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-23		Collection Date: 03/04/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0024	0.015 AL	0.0010	mg/L		03/19/20 1026	03/19/20 1244	LLW

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-24		Collection Date: 03/04/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0030	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1440	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-25		Collection Date: 03/04/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0279	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1451	LLW

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-26		Collection Date: 03/04/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0136	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1455	LLW

Client Sample ID: 78	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-27		Collection Date: 03/04/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1458	LLW

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-28		Collection Date: 03/04/2020 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0159	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1502	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-29		Collection Date: 03/04/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.135	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1506	LLW

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-30		Collection Date: 03/04/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1517	LLW

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-31		Collection Date: 03/04/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0063	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1521	LLW

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-32		Collection Date: 03/04/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1525	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 84	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-33		Collection Date: 03/04/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0022	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1528	LLW

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-34		Collection Date: 03/04/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1532	LLW

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-35		Collection Date: 03/04/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0059	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1540	LLW

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-36		Collection Date: 03/04/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1543	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-37		Collection Date: 03/04/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0030	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1547	LLW

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-38		Collection Date: 03/04/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1551	LLW

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-39		Collection Date: 03/04/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1602	LLW

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-40		Collection Date: 03/04/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0371	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1606	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-41		Collection Date: 03/04/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1609	LLW

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-42		Collection Date: 03/04/2020 7:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0112	0.015 AL	0.0010	mg/L		03/19/20 1156	03/19/20 1613	LLW

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-43		Collection Date: 03/04/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0102	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1317	LLW

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-44		Collection Date: 03/04/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0236	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1258	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 74	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-45		Collection Date: 03/04/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1328	LLW

Client Sample ID: 79	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-46		Collection Date: 03/04/2020 7:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0204	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1331	LLW

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-47		Collection Date: 03/04/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.169	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1335	LLW

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-48		Collection Date: 03/04/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0016	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1339	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-49		Collection Date: 03/04/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		03/20/20 1019	03/20/20 1343	LLW

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-50		Collection Date: 03/04/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0080	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1412	LLW

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-51		Collection Date: 03/04/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1416	LLW

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-52		Collection Date: 03/04/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0040	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1420	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-53		Collection Date: 03/04/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0040	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1423	LLW

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-54		Collection Date: 03/04/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0076	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1401	LLW

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-55		Collection Date: 03/04/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0390	0.015 AL	0.0010	mg/L		03/20/20 1428	03/23/20 1332	DLO

Client Sample ID: 88	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-56		Collection Date: 03/04/2020 6:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0600	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1427	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 91	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-57		Collection Date: 03/04/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0244	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1438	LLW

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-58		Collection Date: 03/04/2020 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0055	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1442	LLW

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-59		Collection Date: 03/04/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1446	LLW

Client Sample ID: 90	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-60		Collection Date: 03/04/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0755	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1450	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-61		Collection Date: 03/04/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0118	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1501	LLW

Client Sample ID: 88	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-62		Collection Date: 03/04/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0056	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1504	LLW

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-63		Collection Date: 03/04/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0098	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1508	LLW

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-64		Collection Date: 03/04/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1512	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 91	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-65		Collection Date: 03/04/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0079	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1453	LLW

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-66		Collection Date: 03/04/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1523	LLW

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-67		Collection Date: 03/04/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0146	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1527	LLW

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-68		Collection Date: 03/04/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0199	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1530	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 14	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-69		Collection Date: 03/04/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0231	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1534	LLW

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-70		Collection Date: 03/04/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.151	0.015 AL	0.0010	mg/L		03/20/20 1428	03/23/20 1334	DLO

Client Sample ID: 90	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-71		Collection Date: 03/04/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0144	0.015 AL	0.0010	mg/L		03/20/20 1234	03/20/20 1538	LLW

Client Sample ID: 65	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-72		Collection Date: 03/04/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0252	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0018	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 77	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-73		Collection Date: 03/04/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0111	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0020	DLO

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-74		Collection Date: 03/04/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0642	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0022	DLO

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-75		Collection Date: 03/04/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0024	DLO

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-76		Collection Date: 03/04/2020 7:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0201	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0011	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 12	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-77		Collection Date: 03/04/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0030	DLO

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-78		Collection Date: 03/04/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0016	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0032	DLO

Client Sample ID: 89	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-79		Collection Date: 03/04/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.186	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0033	DLO

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-80		Collection Date: 03/04/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0030	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0035	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-81		Collection Date: 03/04/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0041	DLO

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-82		Collection Date: 03/04/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0043	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0043	DLO

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-83		Collection Date: 03/04/2020 7:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0023	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0045	DLO

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0646-84		Collection Date: 03/04/2020 7:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0046	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Client Sample ID: 24	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/04/2020 7:08
Lab Sample ID: J0C0646-85	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0424	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0052	DLO

Client Sample ID: 82	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/04/2020 7:04
Lab Sample ID: J0C0646-86	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0233	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0054	DLO

Client Sample ID: 7Ce	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/04/2020 6:42
Lab Sample ID: J0C0646-87	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0298	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0056	DLO

Client Sample ID: 64	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/04/2020 6:08
Lab Sample ID: J0C0646-88	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/20/20 1645	03/21/20 0058	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0646

Definitions

AL: US EPA Action Level
mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549 New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at https://www.microbac.com/standard-terms-conditions.

Reviewed and Approved By:

Shannon Weeks (handwritten signature)

Shannon Weeks
Customer Relationship Coordinator
Reported: 03/30/2020 11:19

WATERLOO U.S.

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>WATERLOO U.S.</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com	fhauck@boces.com
Fax Results:	Yes		

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	Ice: YES NO
89	3/4/20	6:36	DW	DW	YES NO
11		6:50			YES NO
27		6:43			YES NO
29		6:41			YES NO
28		6:41			YES NO
40		6:30			YES NO
78		7:15			YES NO
6		6:49			C W
7		6:46			YES NO
33		6:30			YES NO
41		6:30			YES NO
45		6:25			YES NO
84		6:23			YES NO
50		6:22			YES NO
58		6:22			YES NO
39		6:28			YES NO
44		6:28			YES NO
37		6:26			YES NO
38		6:28			YES NO
52		6:24			YES NO

J O C O 6 4 6
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Number of Containers for Analysis Requested		Comments/Field Data	
1			
Total Lead (EPA 200.8)			
Plastic			
250 ml			
HNO3			
Accepted?	YES NO		
Container Material			
Container Size (in MI)			
Preservative			

Date/Time
 3/4/20
 3/6/2020 8:59/10:45

Print Name and Company
Ernest Sparr
 Ernest Sparr

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: WaterTown H.S.
 Quote ID: Lead Testing PO#:
 Rush TAT Bus. Days: < 2-5 5-7 7-10 Date Req.:
 Carbon Copy: Yes
 Email Results: Yes rffiley@boces.com fhauck@boces.com ishaw@boces.com
 Fax Results: Yes

Billing/Invoice:

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material
 Container size (in MI)
 Preservative

Sample Information		Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested
3	3/4/20	700	DW	DW	1
27		703			
4		643			
5		645			
74		713			
79		716			
8		648			
18		643			
25		643			
42		630			
86		626			
85		625			
43		631			
35		633			
34		631			
88		636			
91		639			
30		634			
36		633			
90		637			


J O C O 6 4 6
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Print Name and Company
 Sampled: *[Signature]*
 Received: *[Signature]*
 Date/Time: 3/4/20
 Comments: 8255/10.18.5

Client Information
 Name: Jeff/Lew Boes
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: WATERLOO H.S.
 Quote ID: Lead Testing PO#
 Rush TAT Bus. Days: < 2-5 5-7 7-10 Date Req.:
 Carbon Copy: Yes
 Email Results: Yes filliev@boces.com, fhauck@boces.com, lshaw@boces.com
 Fax Results: Yes

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material
 Container Size (in MI)
 Preservative

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data
70	3/4/20	713	DW	1	
88		635			
15		653			
82		700			
91		702			
1		648			
69		710			
68		710			
14		657			
2		651			
90		702			
65		705			
77		700			
23		707			
19		645			
66		711			
12		653			
22		713			
89		702			
83		700			



Print Name and Company
 Sampled: [Signature]
 Received: Ernest Spear
 Date/Time: 3/4/20
 Comments: 3/6/2020 8:55/10:45

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

