



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0C0635

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Knickerbocker Elem.

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: Knickerbocker Elem.
 Received: 03/06/2020
 Reported: 04/07/2020

Analytical Testing Parameters

Client Sample ID: 84	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:12
Lab Sample ID: J0C0635-01	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/02/20 1309	04/02/20 1413	DLO

Client Sample ID: 36	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:22
Lab Sample ID: J0C0635-02	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1449	DLO

Client Sample ID: 37	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:22
Lab Sample ID: J0C0635-03	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0032	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1455	DLO

Client Sample ID: 4C	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:06
Lab Sample ID: J0C0635-04	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1456	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 12	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-05		Collection Date: 03/03/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1458	DLO

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-06		Collection Date: 03/03/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1500	DLO

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-07		Collection Date: 03/03/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0034	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1502	DLO

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-08		Collection Date: 03/03/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0039	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1507	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-09		Collection Date: 03/03/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0107	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1509	DLO

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-10		Collection Date: 03/03/2020 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0049	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1511	DLO

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-11		Collection Date: 03/03/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0043	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1513	DLO

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-12		Collection Date: 03/03/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0069	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1515	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-13		Collection Date: 03/03/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0034	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1518	DLO

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-14		Collection Date: 03/03/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0036	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1520	DLO

Client Sample ID: 4A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-15		Collection Date: 03/03/2020 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1522	DLO

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-16		Collection Date: 03/03/2020 6:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1524	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-17		Collection Date: 03/03/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0079	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1529	DLO

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-18		Collection Date: 03/03/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0060	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1531	DLO

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-19		Collection Date: 03/03/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0078	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1533	DLO

Client Sample ID: 3A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-20		Collection Date: 03/03/2020 6:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0034	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1535	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-21		Collection Date: 03/03/2020 6:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/20 1422	04/01/20 1537	DLO

Client Sample ID: 50B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-22		Collection Date: 03/03/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1546	DLO

Client Sample ID: 50A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-23		Collection Date: 03/03/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1551	DLO

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-24		Collection Date: 03/03/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1553	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-25		Collection Date: 03/03/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0134	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1555	DLO

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-26		Collection Date: 03/03/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1557	DLO

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-27		Collection Date: 03/03/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0091	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1559	DLO

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-28		Collection Date: 03/03/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0035	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1604	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-29		Collection Date: 03/03/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0043	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1606	DLO

Client Sample ID: 81	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-30		Collection Date: 03/03/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1608	DLO

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-31		Collection Date: 03/03/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1610	DLO

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-32		Collection Date: 03/03/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0049	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1611	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-33		Collection Date: 03/03/2020 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1615	DLO

Client Sample ID: 4B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-34		Collection Date: 03/03/2020 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0023	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1617	DLO

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-35		Collection Date: 03/03/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0061	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1619	DLO

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-36		Collection Date: 03/03/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1621	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-37		Collection Date: 03/03/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1626	DLO

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-38		Collection Date: 03/03/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0023	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1628	DLO

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-39		Collection Date: 03/03/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1630	DLO

Client Sample ID: 31	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-40		Collection Date: 03/03/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0032	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1632	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-41		Collection Date: 03/03/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.193	0.015 AL	0.0102	mg/L		04/01/20 1425	04/02/20 1201	DLO

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-42		Collection Date: 03/03/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0023	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1648	DLO

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-43		Collection Date: 03/03/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0029	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1650	DLO

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-44		Collection Date: 03/03/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0064	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1652	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-45		Collection Date: 03/03/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0039	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1654	DLO

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-46		Collection Date: 03/03/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0051	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1655	DLO

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-47		Collection Date: 03/03/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0051	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1701	DLO

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-48		Collection Date: 03/03/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1703	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 64	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-49		Collection Date: 03/03/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.840	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1705	DLO

Client Sample ID: 60	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-50		Collection Date: 03/03/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1707	DLO

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-51		Collection Date: 03/03/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0468	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1708	DLO

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-52		Collection Date: 03/03/2020 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0056	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1712	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-53		Collection Date: 03/03/2020 6:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0045	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1714	DLO

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-54		Collection Date: 03/03/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0104	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1716	DLO

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-55		Collection Date: 03/03/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1717	DLO

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-56		Collection Date: 03/03/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0039	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1723	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-57		Collection Date: 03/03/2020 9:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1725	DLO

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-58		Collection Date: 03/03/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1727	DLO

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-59		Collection Date: 03/03/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0857	0.015 AL	0.0010	mg/L		04/01/20 1425	04/01/20 1728	DLO

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-60		Collection Date: 03/03/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0593	0.015 AL	0.0020	mg/L		04/01/20 1425	04/02/20 1210	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 3B	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:03
Lab Sample ID: J0C0635-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0015	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1739	DLO

Client Sample ID: 5	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:09
Lab Sample ID: J0C0635-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0032	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1745	DLO

Client Sample ID: 9	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:05
Lab Sample ID: J0C0635-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0061	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1747	DLO

Client Sample ID: 34	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:15
Lab Sample ID: J0C0635-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1749	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-65		Collection Date: 03/03/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0053	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1750	DLO

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-66		Collection Date: 03/03/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1752	DLO

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-67		Collection Date: 03/03/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0063	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1758	DLO

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-68		Collection Date: 03/03/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0026	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1800	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-69		Collection Date: 03/03/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1801	DLO

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-70		Collection Date: 03/03/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0045	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1803	DLO

Client Sample ID: 77	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-71		Collection Date: 03/03/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0081	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1805	DLO

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-72		Collection Date: 03/03/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0122	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1809	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-73		Collection Date: 03/03/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0071	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1811	DLO

Client Sample ID: 75	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-74		Collection Date: 03/03/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1813	DLO

Client Sample ID: 87	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-75		Collection Date: 03/03/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0063	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1814	DLO

Client Sample ID: 79	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-76		Collection Date: 03/03/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1820	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-77		Collection Date: 03/03/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0036	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1822	DLO

Client Sample ID: 78	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-78		Collection Date: 03/03/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0885	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1824	DLO

Client Sample ID: 88	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-79		Collection Date: 03/03/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0113	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1825	DLO

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0635-80		Collection Date: 03/03/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1426	04/01/20 1827	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Client Sample ID: 80	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 7:40
Lab Sample ID: J0C0635-81	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/01/20 1424	04/01/20 1633	DLO

Client Sample ID: 44	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:25
Lab Sample ID: J0C0635-82	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0060	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1301	DLO

Client Sample ID: 59	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/03/2020 6:37
Lab Sample ID: J0C0635-83	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0070	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1303	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0635

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Shannon Weeks". The signature is written in a cursive style and is positioned above a light blue rectangular background.

Shannon Weeks

Customer Relationship Coordinator

Reported: 04/07/2020 14:45

Knickelbecker Elm


Client Information
Name: Jeff/Lew Boces
Address: 20104 NYS Route 3
Contact: Health/Safety Dept.
Phone: 315-779-7000
Project: *Knickelbecker Elm*
Quote ID: *Lead Testing* PO#:
Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req:
Carbon Copy: Yes
Email Results: Yes *rfliley@boces.com, fhauck@boces.com, lshaw@boces.com*
Fax Results: Yes

Billing/Invoice:

Analysis Requested

Total Lead (EPA 200.8)

Sample Information			Matrix	
Description/Location	Date	Time	Type	Matrix
1				
2	3/3/20	6:12	DW	
3		6:22		
4		6:22		
5		6:40		
6		6:16		
7		6:17		
8		6:23		
9		6:12		
10		6:15		
11		6:13		
12		6:10		
13		6:10		
14		6:17		
15		6:23		
16		6:40		
17		6:04		
18		6:05		
19		6:05		
20		6:09		
		6:03		



Receiving Info (Lab Use Only)

Ice: YES NO
Cooler: YES NO
Sample Temp: *N/A*
Cooler Seal: YES NO
Pickup: YES NO
Dropoff: C W
Accepted? YES NO

Container Material
Container size(In MI)
Preservative

Comments/Field Data

Number of Containers for Analysis Requested

Date/Time: 3/3/20
3/6/2020
3/17/20 10:45

Comments: *8:55/10:45*

Print Name and Company
Sampled: *Paula Amadio*
Received: *James Spencer*
Received: *Paula Amadio*

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY00895

Samples must be returned on ice
MNY Workorder #


Kuckelbrocker ELEM

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boccs		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Kuckelbrocker ELEM</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boccs.com, fhauck@boccs.com, lshaw@boccs.com	
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Type	
49	3/3/20	6:27	DW	
50B		6:22		
50A		6:22		
54		6:25		
55		6:25		
46		6:17		
24		6:14		
43		6:24		
32		6:21		
81		6:16		
48		6:26		
25		6:14		
85		6:18		
4B		6:06		
63		6:10		
27		6:11		
82		6:16		
28		6:11		
29		6:11		
31		6:20		

Analysis Requested	Number of Containers for Analysis Requested	Comments/Field Data
Total Lead (EPA 200.8)	1	
Plastic		
250 ml		
HNO3		

Receiving Info (Lab Use Only)	Accepted?
Ice: YES NO	YES NO
Cooler: YES NO	YES NO
Sample Temp: <i>NAC</i>	YES NO
Cooler Seal: YES NO	YES NO
Pickup: YES NO	YES NO
Dropoff: C W	



J0C0635

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
PM: Shannon Weeks

Sampled:	Received:	Received:	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/3/20	
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/16/2020	8:55/10:26
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/16/20	10:15

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

3821 Buck Drive
 Cortland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

Katherine Becke ELEM

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Katherine Becke ELEM</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfliley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Type	
53	3/3/20	6:31	DW	
83		6:12		
30		12:20		
		6:30		
		6:33		
		6:32		
		6:31		
		6:35		
		6:35		
		6:28		
		6:30		
		6:34		
		6:29		
		6:20		
		12:20		
		6:20		
		6:29		
		12:01		
		5:25		
		6:28		

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	N/A
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material:	
Container size (in MI):	
Preservative:	
Comments/Field Data	
J 0 C 0 6 3 5 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks	

Number of Containers for Analysis Requested	Date/Time	Comments
1	3/3/20	
	3/6/2020	8:55/10:45
	3/16/20	10:45

Print Name and Company
Katherine Becke ELEM
Ernest Spener
Karla Conway

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY
 MNY Workorder #

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Kwicker Becker Elem.

Client Information Name: Jeff/Lew Boces Address: 20104 NYS Route 3 Contact: Health/Safety Dept. Phone: 315-779-7000 Project: <i>Kwicker Becker Elem</i> Quote ID: Lead Testing Rush TAT Bus. Days: 2-5 5-7 7-10 Carbon Copy: Yes Email Results: Yes Fax Results: Yes		Billing/Invoice: PO#: _____ Date Req.: _____ Billing/Invoice: _____	
Total Lead (EPA 200.8) Plastic 250 ml HNO3 1		Analysis Requested	

1	Sample Information			Matrix	
	Description/Location	Date	Time	Type	Type
2	3B	3/3/20	1003	DW	
3	3		1009		
4	9		1005		
5	34		1005		
6	15		1005		
7	35		1015		
8	10		1009		
9	76		1039		
10	73		1038		
11	108		1035		
12	77		1038		
13	69		1037		
14	70		1037		
15	75		1039		
16	87		1010		
17	79		1010		
18	78		1011		
19	88		1039		
20	72		1045		
			1030		



Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Sampled: <i>[Signature]</i>	Date/Time: 3/3/20	Comments:
Received: <i>[Signature]</i>	Date/Time: 3/6/2020 8:55/10:55	
Received: <i>[Signature]</i>	Date/Time: 3/17/20	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
Cortland NY 13045
Phone: (607)753-3403 Fax: (607)753-3415
NY #10795, EPA #NY00935

Knickerbocker ELEM

Samples must be returned on ice
MNY Workorder #

Client Information		Billing/Invoices:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	Knickerbocker ELEM		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	Email:	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Type	Type
84	3/3/20	6:12	DW	
36		6:22		
37		6:22		
4C		6:06		
12		6:10		
39		6:17		
38		6:23		
18		6:12		
33		6:15		
19		6:13		
22		6:10		
21		6:10		
41		6:17		
39		6:23		
4A		6:00		
2		6:04		
8		6:05		
10		6:05		
6		6:09		
3A		6:03		

Receiving Info (Lab Use Only)		Analysis Requested	
Ice:	YES NO		
Cooler:	YES NO		
Sample Temp:	N/A		
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES NO		
Container Material:			
Container Size (In MI):			
Preservative:			
Comments/Field Data:	J0C0635 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks		

Number of Containers for Analysis Requested	1	Date/Time	3/3/20	Comments
			3/6/2020	8:55/10:45
			3/17/20	10:45
Sampled:	<i>[Signature]</i>	Print Name and Company		
Received:	<i>[Signature]</i>			
Received:	<i>[Signature]</i>			

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY000935

Samples must be returned on ice
 MNY Workorder #


Kuckelbecker Elem

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Kuckelbecker Elem</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	Email:	rfilley@boces.com, ffrauck@boces.com, lshaw@boces.com
Fax Results:	Yes		

Sample Information			
Description/Location	Date	Time	Matrix Type
49	3/3/20	6:27	DW
50B		6:22	
50A		6:22	
54		6:28	
65		6:25	
46		6:17	
24		6:14	
43		6:24	
32		6:21	
81		6:16	
48		6:26	
25		6:14	
85		6:18	
4B		6:06	
13		6:10	
27		6:11	
82		6:16	
28		6:11	
29		6:11	
31		6:20	

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	<i>NAK</i>
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	<i>YES</i> NO
Container Material:	
Container Size (in Mi)	
Preservative	

Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Parameter	Method	Count	Notes	Comments	Field Data
Total Lead (EPA 200.8)		1			
Plastic					
250 ml					
HNO3					



J 0 C 0 6 3 5

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Sampled:	Received:	Received:	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/3/20	
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/6/20	8:55/10:26
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/6/20	10:15

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY MNY Workorder #

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY008935

Kaucher Becker Elem


Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Kaucher Becker Elem</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information		Matrix	
Description/Location	Date	Time	Type
1	3/3/20	6:31	DW
2		6:12	
3		6:20	
4		6:30	
5		6:33	
6		6:32	
7		6:31	
8		6:35	
9		6:35	
10		6:28	
11		6:30	
12		6:34	
13		6:29	
14		6:20	
15		6:20	
16		6:24	
17		6:29	
18		6:24	
19		6:25	
20		6:28	

Total Lead (EPA 200.8)	Plastic	250 ml	HNO3	1
------------------------	---------	--------	------	---

Number of Containers for Analysis Requested	Comments/Field Data
---	---------------------

Receiving Info (Lab Use Only)
Ice: YES NO
Cooler: YES NO
Sample Temp: N/A
Cooler Seal: YES NO
Pickup: YES NO
Dropoff: C W
Accepted? YES NO
Container Material
Container size (in MI)
Preservative



Print Name and Company	Date/Time	Comments
<i>Kaucher Becker Elem</i>	3/3/20	
<i>Kaucher Becker Elem</i>	3/4/2020	8:55/10:45
<i>Kaucher Becker Elem</i>	3/4/20 10:45	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY # 10795, EPA # NY00935

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY

Kwickbacker Elem.

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Kwickbacker Elem</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	<i>N/A</i>
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Container Material	
Container size (in Mi)	
Preservative	

Plastic	
250 ml	
HNO3	

Sample Information		Matrix	
Description/Location	Date	Time	Type
<i>3B</i>	<i>3/3/20</i>	<i>603</i>	DW
<i>3</i>	<i>609</i>		
<i>9</i>	<i>605</i>		
<i>34</i>	<i>605</i>		
<i>15</i>	<i>605</i>		
<i>35</i>	<i>605</i>		
<i>10</i>	<i>609</i>		
<i>76</i>	<i>639</i>		
<i>73</i>	<i>638</i>		
<i>68</i>	<i>635</i>		
<i>77</i>	<i>638</i>		
<i>69</i>	<i>637</i>		
<i>70</i>	<i>639</i>		
<i>75</i>	<i>610</i>		
<i>87</i>	<i>640</i>		
<i>79</i>	<i>641</i>		
<i>78</i>	<i>639</i>		
<i>88</i>	<i>645</i>		
<i>72</i>	<i>630</i>		

Number of Containers for Analysis Requested		Comments/Field Data	
1			

J 0 C 0 6 3 5
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Print Name and Company		Date/Time	Comments
<i>[Signature]</i>		<i>3/3/20</i>	
<i>EMPS + Spencer</i>		<i>3/6/2020 8:55/10:45</i>	
<i>Natalia Goumar</i>		<i>3/11/20</i>	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____


Knickerbaker Elem.

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>Knickerbaker Elem.</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfiley@boces.com	fhauck@boces.com
Fax Results:	Yes		

Sample Information			
	Description/Location	Date	Time
1	<i>80</i>	<i>3/5/20</i>	<i>740</i>
2	<i>44</i>	<i>3/3/20</i>	<i>625</i>
3	<i>59</i>	<i>3/3/20</i>	<i>637</i>
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	<i>N/A</i>
Cooler seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Container Material:	
Container Size (in MI)	
Preservative	

Analysis Requested		Number of Containers for Analysis Requested	
Total Lead (EPA 200.8)	Plastic	1	
	250 ml		
	HNO3		



J0C0635
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Sampled	Received	Received	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>3/3/20</i>	
	<i>James A. Spener</i>	<i>[Signature]</i>	<i>3/6/2020</i>	<i>8:55/20:46</i>
	<i>Paula Carver</i>	<i>[Signature]</i>	<i>3/6/20</i>	<i>PM</i>

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.