



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0C0667

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Watertown M.S.

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 03/06/2020
 Reported: 04/07/2020

Analytical Testing Parameters

Client Sample ID: 46								
Sample Matrix: Drinking Water					Collected By: RF-Client			
Lab Sample ID: J0C0667-01					Collection Date: 03/05/2020 6:35			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0030	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1055	LLW

Client Sample ID: 25								
Sample Matrix: Drinking Water					Collected By: RF-Client			
Lab Sample ID: J0C0667-02					Collection Date: 03/05/2020 6:22			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0042	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1106	LLW

Client Sample ID: 87								
Sample Matrix: Drinking Water					Collected By: RF-Client			
Lab Sample ID: J0C0667-03					Collection Date: 03/05/2020 6:27			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0036	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1110	LLW

Client Sample ID: 2								
Sample Matrix: Drinking Water					Collected By: RF-Client			
Lab Sample ID: J0C0667-04					Collection Date: 03/05/2020 6:05			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0061	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1113	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-05		Collection Date: 03/05/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0143	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1117	LLW

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-06		Collection Date: 03/05/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0032	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1121	LLW

Client Sample ID: 16B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-07		Collection Date: 03/05/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1132	LLW

Client Sample ID: 27B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-08		Collection Date: 03/05/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1136	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-09		Collection Date: 03/05/2020 6:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0016	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1139	LLW

Client Sample ID: 56B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-10		Collection Date: 03/05/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1143	LLW

Client Sample ID: 71B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-11		Collection Date: 03/05/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1147	LLW

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-12		Collection Date: 03/05/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1154	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-13		Collection Date: 03/05/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1158	LLW

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-14		Collection Date: 03/05/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0079	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1202	LLW

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-15		Collection Date: 03/05/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1205	LLW

Client Sample ID: 88	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-16		Collection Date: 03/05/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0041	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1216	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-17		Collection Date: 03/05/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0113	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1220	LLW

Client Sample ID: 71A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-18		Collection Date: 03/05/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1224	LLW

Client Sample ID: 59	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-19		Collection Date: 03/05/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0059	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1227	LLW

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-20		Collection Date: 03/05/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		04/01/20 1021	04/01/20 1231	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-21		Collection Date: 03/05/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1250	LLW

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-22		Collection Date: 03/05/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1301	LLW

Client Sample ID: 15A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-23		Collection Date: 03/05/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1305	LLW

Client Sample ID: 12A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-24		Collection Date: 03/05/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1308	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 12B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-25		Collection Date: 03/05/2020 6:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1312	LLW

Client Sample ID: 8B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-26		Collection Date: 03/05/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0035	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1316	LLW

Client Sample ID: 10A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-27		Collection Date: 03/05/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1327	LLW

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-28		Collection Date: 03/05/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0120	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1331	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-29		Collection Date: 03/05/2020 6:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1335	LLW

Client Sample ID: 27A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-30		Collection Date: 03/05/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1338	LLW

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-31		Collection Date: 03/05/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0041	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1342	LLW

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-32		Collection Date: 03/05/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0015	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1349	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 74	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-33		Collection Date: 03/05/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0022	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1353	LLW

Client Sample ID: 78	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-34		Collection Date: 03/05/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0098	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1357	LLW

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-35		Collection Date: 03/05/2020 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0088	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1401	LLW

Client Sample ID: 75	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-36		Collection Date: 03/05/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0098	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1412	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-37		Collection Date: 03/05/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0084	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1416	LLW

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-38		Collection Date: 03/05/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0073	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1419	LLW

Client Sample ID: 70B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-39		Collection Date: 03/05/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1423	LLW

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-40		Collection Date: 03/05/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0042	0.015 AL	0.0010	mg/L		04/01/20 1209	04/01/20 1427	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-41		Collection Date: 03/05/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1256	DLO

Client Sample ID: 55B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-42		Collection Date: 03/05/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1301	DLO

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-43		Collection Date: 03/05/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1303	DLO

Client Sample ID: 7B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-44		Collection Date: 03/05/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1305	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 45B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-45		Collection Date: 03/05/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1306	DLO

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-46		Collection Date: 03/05/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1308	DLO

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-47		Collection Date: 03/05/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0064	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1314	DLO

Client Sample ID: 7A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-48		Collection Date: 03/05/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1316	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-49		Collection Date: 03/05/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0038	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1317	DLO

Client Sample ID: 45A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-50		Collection Date: 03/05/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1319	DLO

Client Sample ID: 9B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-51		Collection Date: 03/05/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1321	DLO

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-52		Collection Date: 03/05/2020 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0074	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1325	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 10B	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:20
Lab Sample ID: J0C0667-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1327	DLO

Client Sample ID: 19	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:21
Lab Sample ID: J0C0667-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0033	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1328	DLO

Client Sample ID: 52	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:43
Lab Sample ID: J0C0667-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0041	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1330	DLO

Client Sample ID: 85	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:19
Lab Sample ID: J0C0667-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1336	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 8A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-57		Collection Date: 03/05/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1338	DLO

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-58		Collection Date: 03/05/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1339	DLO

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-59		Collection Date: 03/05/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0050	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1341	DLO

Client Sample ID: 15B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-60		Collection Date: 03/05/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1240	04/01/20 1343	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 89	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-61		Collection Date: 03/05/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1352	DLO

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-62		Collection Date: 03/05/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0104	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1358	DLO

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-63		Collection Date: 03/05/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0024	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1400	DLO

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-64		Collection Date: 03/05/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0098	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1401	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-65		Collection Date: 03/05/2020 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0120	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1403	DLO

Client Sample ID: 16A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-66		Collection Date: 03/05/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1405	DLO

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-67		Collection Date: 03/05/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0036	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1411	DLO

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-68		Collection Date: 03/05/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0046	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1412	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 55A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-69		Collection Date: 03/05/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1414	DLO

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-70		Collection Date: 03/05/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0028	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1416	DLO

Client Sample ID: 84A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-71		Collection Date: 03/05/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1418	DLO

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-72		Collection Date: 03/05/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0024	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1422	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 84B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-73		Collection Date: 03/05/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1423	DLO

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-74		Collection Date: 03/05/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1425	DLO

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-75		Collection Date: 03/05/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0162	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1427	DLO

Client Sample ID: 14B	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-76		Collection Date: 03/05/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1433	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 14A	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:16
Lab Sample ID: J0C0667-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1434	DLO

Client Sample ID: 5	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:08
Lab Sample ID: J0C0667-78	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0058	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1436	DLO

Client Sample ID: 9A	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:08
Lab Sample ID: J0C0667-79	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1438	DLO

Client Sample ID: 30	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 6:25
Lab Sample ID: J0C0667-80	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0065	0.015 AL	0.0010	mg/L		04/01/20 1241	04/01/20 1440	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-81		Collection Date: 03/05/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0031	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1247	DLO

Client Sample ID: 56A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-82		Collection Date: 03/05/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1243	DLO

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-83		Collection Date: 03/05/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1245	DLO

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-84		Collection Date: 03/05/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1250	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-85		Collection Date: 03/05/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0054	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1252	DLO

Client Sample ID: 70A	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-86		Collection Date: 03/05/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1254	DLO

Client Sample ID: 77	Sample Matrix: Drinking Water	Collected By: RF-Client
Lab Sample ID: J0C0667-87		Collection Date: 03/05/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/02/20 1133	04/02/20 1256	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0667

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Shannon Weeks". The signature is written in a cursive style and is positioned above a light blue rectangular background.

Shannon Weeks

Customer Relationship Coordinator

Reported: 04/07/2020 14:45

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY00935

Examples must be returned on ice
MNY Workorder #

WATERBURY M.S.

Client Information			Billing/Invoice:		
Name:	Jeff/Lew Boces				
Address:	20104 NYS Route 3				
Contact:	Health/Safety Dept.				
Phone:	315-779-7000				
Project:	<i>WATERBURY M.S.</i>				
Quote ID:	Lead Testing	PO#:			
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:			
Carbon Copy:	Yes				
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, ishaw@boces.com			
Fax Results:	Yes				

Sample Information				Analysis Requested				Receiving Info (Lab Use Only)	
	Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Container Material	Ice:	YES NO
1	<i>46</i>	<i>3/5/20</i>	<i>6:35</i>		DW		Plastic	Cooler:	YES NO
2	<i>25</i>		<i>6:22</i>				250 ml	Sample Temp:	YES NO
3	<i>87</i>		<i>6:27</i>				HINO3	Cooler Seal:	YES NO
4	<i>2</i>		<i>6:05</i>					Pickup:	YES NO
5	<i>1</i>		<i>6:05</i>					Dropoff:	C W
6	<i>83</i>		<i>6:05</i>					Accepted?	YES NO
7	<i>16B</i>		<i>6:23</i>					Container Material	
8	<i>27B</i>		<i>6:01</i>					Container Size (in MI)	
9	<i>69</i>		<i>6:49</i>					Preservative	
10	<i>56B</i>		<i>6:51</i>					Comments/Field Data	
11	<i>71B</i>		<i>6:55</i>						
12	<i>36</i>		<i>6:25</i>						
13	<i>20</i>		<i>1:21</i>						
14	<i>32</i>		<i>6:15</i>						
15	<i>68</i>		<i>6:48</i>						
16	<i>88</i>		<i>6:46</i>						
17	<i>61</i>		<i>6:52</i>						
18	<i>71A</i>		<i>6:50</i>						
19	<i>59</i>		<i>6:51</i>						
20	<i>66a</i>		<i>6:50</i>						

Sampled:	Received:	Received:	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>3/5/20</i>	
			<i>3/6/20</i>	<i>1085</i>



Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
PM: Shannon Weeks

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

1085

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

3821 Buck Drive
Cortland NY 13045
Phone: (607)753-3403 Fax: (607)753-3415
NY #10795, EPA #NY00935

WATERBORN M.S.

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: WATERBORN M.S.
 Quote ID: Lead Testing
 PO#:
 Date Req:
 Rush TAT Bus. Days: <2 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 rfilley@boces.com, fhauck@boces.com, lshaw@boces.com

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? (YES) NO

Container Material
 Container Size (in MI)
 Preservative

Sample Information		Matrix	
Description/Location	Date	Time	Type
1 33	3/5/20	6015	DW
2 4		6000	
3 15A		6009	
4 12A		6010	
5 13B		6003	
6 8B		6014	
7 10A		6020	
8 28		6023	
9 11		6029	
10 27A		6011	
11 62		6032	
12 76		6055	
13 74		6051	
14 78		6055	
15 34		6018	
16 75		6057	
17 72		6058	
18 41		6037	
19 70B		6045	
20 23		6022	

J 0 C 0 6 6 7
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Analysis Requested

Total Lead (EPA 200.8)
 Plastic
 250 ml
 HNO3

Number of Containers for Analysis Requested

1

Comments/Field Data

Comments

Date/Time: 3/5/20

Received: [Signature]
 Received: [Signature]
 Received: Karla Conway 3/6/20 10:45

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

2015

WATERLOO M.S

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	WATERLOO M.S		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

Sample Information		Matrix	
Description/Location	Date	Time	Type
89	3/5/20	700	DW
37		628	
38		628	
39		628	
80a		619	
16A		623	
47		641	
42		638	
55A		637	
48		641	
8A		609	
18		623	
81B		609	
17		631	
43		638	
14B		616	
14A		616	
5		608	
9A		608	
30		625	

Receiving Info (Lab Use Only)		Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Ice:	YES NO						
Cooler:	YES NO						
Sample Temp:	N/A						
Cooler Seal:	YES NO						
Pickup:	YES NO						
Dropoff:	C W						
Accepted?	YES NO						
Container Material							
Container Size (in MI)							
Preservative							

Sampled:	Received:	Received:	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/5/20	
		Karla Conway	3/6/20 185	

J 0 C 0 6 6 7
Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
PM: Shannon Weeks

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

4085

