



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0C0281

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Sherman Elementary

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 02/28/2020
 Reported: 03/18/2020

Analytical Testing Parameters

Client Sample ID: 28								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0C0281-01					Collection Date: 02/27/2020 6:00			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1504	DLO

Client Sample ID: 59								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0C0281-02					Collection Date: 02/27/2020 6:00			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0011	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1510	DLO

Client Sample ID: 27								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0C0281-03					Collection Date: 02/27/2020 6:02			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1511	DLO

Client Sample ID: 22								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0C0281-04					Collection Date: 02/27/2020 6:05			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0022	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1513	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-05		Collection Date: 02/27/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0067	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1515	DLO

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-06		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0028	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1517	DLO

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-07		Collection Date: 02/27/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1522	DLO

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-08		Collection Date: 02/27/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1524	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-09		Collection Date: 02/27/2020 6:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0157	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1526	DLO

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-10		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0093	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1528	DLO

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-11		Collection Date: 02/27/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1530	DLO

Client Sample ID: 31	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-12		Collection Date: 02/27/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0044	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1533	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 65	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-13		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1535	DLO

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-14		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0046	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1537	DLO

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-15		Collection Date: 02/27/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1539	DLO

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-16		Collection Date: 02/27/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.126	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1544	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-17		Collection Date: 02/27/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0057	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1546	DLO

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-18		Collection Date: 02/27/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0092	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1548	DLO

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-19		Collection Date: 02/27/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0031	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1550	DLO

Client Sample ID: 64	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-20		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		03/12/20 1450	03/12/20 1552	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-21		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1601	DLO

Client Sample ID: 12	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-22		Collection Date: 02/27/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1606	DLO

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-23		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1608	DLO

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-24		Collection Date: 02/27/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1610	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-25		Collection Date: 02/27/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0030	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1612	DLO

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-26		Collection Date: 02/27/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0021	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1614	DLO

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-27		Collection Date: 02/27/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1619	DLO

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-28		Collection Date: 02/27/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1621	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-29		Collection Date: 02/27/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1623	DLO

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-30		Collection Date: 02/27/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0020	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1625	DLO

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-31		Collection Date: 02/27/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0127	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1626	DLO

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-32		Collection Date: 02/27/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0035	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1630	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-33		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0055	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1632	DLO

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-34		Collection Date: 02/27/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1634	DLO

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-35		Collection Date: 02/27/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1636	DLO

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-36		Collection Date: 02/27/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1641	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-37		Collection Date: 02/27/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1643	DLO

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-38		Collection Date: 02/27/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1645	DLO

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-39		Collection Date: 02/27/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0089	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1647	DLO

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-40		Collection Date: 02/27/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0045	0.015 AL	0.0010	mg/L		03/12/20 1451	03/12/20 1648	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-41		Collection Date: 02/27/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1658	DLO

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-42		Collection Date: 02/27/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0288	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1703	DLO

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-43		Collection Date: 02/27/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1705	DLO

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-44		Collection Date: 02/27/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0055	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1707	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-45		Collection Date: 02/27/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0067	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1709	DLO

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-46		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0156	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1710	DLO

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-47		Collection Date: 02/27/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1716	DLO

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-48		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1718	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-49		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0028	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1720	DLO

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-50		Collection Date: 02/27/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1721	DLO

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-51		Collection Date: 02/27/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1723	DLO

Client Sample ID: 14	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-52		Collection Date: 02/27/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1727	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-53		Collection Date: 02/27/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1729	DLO

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-54		Collection Date: 02/27/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1731	DLO

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-55		Collection Date: 02/27/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0027	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1732	DLO

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-56		Collection Date: 02/27/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1738	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-57		Collection Date: 02/27/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1740	DLO

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-58		Collection Date: 02/27/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1742	DLO

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-59		Collection Date: 02/27/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.218	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1743	DLO

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-60		Collection Date: 02/27/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0099	0.015 AL	0.0010	mg/L		03/12/20 1452	03/12/20 1745	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-61		Collection Date: 02/27/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1754	DLO

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-62		Collection Date: 02/27/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0069	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1800	DLO

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-63		Collection Date: 02/27/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1802	DLO

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-64		Collection Date: 02/27/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1804	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-65		Collection Date: 02/27/2020 6:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0069	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1805	DLO

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-66		Collection Date: 02/27/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0037	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1807	DLO

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-67		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0074	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1813	DLO

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0C0281-68		Collection Date: 02/27/2020 6:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0121	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1815	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0281

Client Sample ID: 67	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:10
Lab Sample ID: J0C0281-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1816	DLO

Client Sample ID: 60	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:00
Lab Sample ID: J0C0281-70	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0087	0.015 AL	0.0010	mg/L		03/12/20 1448	03/12/20 1818	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 03/18/2020 17:05

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

SAERMAN

Client Information

Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: SAERMAN JEM
 Quote ID: Lead Testing
 Rush TAT Bus. Days: < 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:

Email: rfilley@boces.com, fhauck@boces.com, lshaw@boces.com
 PO#: _____
 Date Req.: _____

Analysis Requested

Total Lead (EPA 200.8)

Receiving Info (Lab Use Only)

Ice: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO


Container Material
 Plastic

Container Size (in ml)
 250 ml

Preservative
 HNO3

Comments/Field Data

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	Sample Information		Matrix Type
																				Description/Location	Date	
																					1	DW



Print Name and Company

Sampled: Paul Jeff
 Received: Ernest Spencer
 Received: Paul Korman

Date/Time
 2/27
 2/28/2020 2:00/15:25
 2/28/2020 135

Comment

By signing this document, you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY00835

SHERMAN

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>SHERMAN ELEMENTARY</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fnauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Type	
34	2/26	605	DW	
12		608		
33		605		
7		610		
6		611		
9		615		
40		607		
35		607		
10		608		
36		608		
37		608		
2		605		
1		605		
46		630		
45		628		
3		628		
44		625		
43		625		

Receiving Info (Lab Use Only)		Analysis Requested	
Ice:	YES NO		
Cooler:	YES NO		
Sample Temp:	<i>N/A</i>		
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Container Material:			
Container Size (in MI)			
Preservative			
Comments/Field Data			

Number of Containers for Analysis Requested		Comments	
Material	Quantity	Date/Time	Comments
Plastic	1		
250 ml			
HNO3			
		2/26/09	
		2/28/09 20:00	13:25
		2/28/09 13:25	

Sample Information		Matrix	
Description/Location	Date	Time	Type
34	2/26	605	DW
12		608	
33		605	
7		610	
6		611	
9		615	
40		607	
35		607	
10		608	
36		608	
37		608	
2		605	
1		605	
46		630	
45		628	
3		628	
44		625	
43		625	

Print Name and Company		Date/Time	
Sampled	Received	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	2/26/09	
<i>[Signature]</i>	<i>[Signature]</i>	2/28/09 20:00	13:25
<i>[Signature]</i>	<i>[Signature]</i>	2/28/09 13:25	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00835

Microbac Laboratories, Inc.
CHAIN OF CUSTODY


Samples must be returned on ice
 MNY Workorder #

STELMAN

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: *STELMAN ELEM.*
 Quote ID: *Lead Testing*
 Rush TAT Bus. Days: 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 PO#: _____
 Date Req.: _____

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: *N/A*
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material: _____
 Container Size (in MI): _____
 Preservative: _____

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Type			
5	7/24	6:20	DW	1		 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks
42		6:20				
41		6:20				
8		6:16				
39		6:10				
52		6:45				
30		6:40				
51		6:45				
19		6:45				
54		6:30				
16		6:38				
14		6:30				
15		6:32				
48		6:39				
49		6:35				
17		6:35				
38		7:00				
57		6:59				
27		6:37				
56		6:59				

Analysis Requested

Total Lead (EPA 200.8)
 Plastic
 250 ml
 HNO3

Comments

Date/Time: 7/24
 7/24/2020 8:00 / 15:25
 7/28/20 19:15

Print Name and Company: *Ernest Spencer*
Ernest Spencer
Ernest Spencer

Sampled: _____
 Received: _____
 Received: _____

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY
 Samples must be returned on ice
 MNY Workorder #

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Sherman

Client Information		Billing/Invoice:	
Name: Jeff/Lew Boces	Address: 20104 NYS Route 3		
Contact: Health/Safety Dept.	Phone: 315-779-7000		
Project: <i>SHERMAN ELEM.</i>	Quote ID: Lead Testing		
Rush TAT Bus. Days: < 2-5 5-7 7-10	Carbon Copy: Yes		
Email Results: Yes	Fax Results: Yes		
Email: rfilley@boces.com, fhauck@boces.com, ishaw@boces.com			

Sample Information		Matrix		
Description/Location	Date	Time	Type	
29	5/26	6:55	DW	
55		6:55		
18		6:40		
11		6:50		
13		6:49		
26		7:00		
53		6:45		

efferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks




Number of Containers for Analysis Requested	Analysis Requested	Receiving Info (Lab Use Only)
1		Ice: YES NO Cooler: YES NO Sample Temp: N/A Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted: YES NO
Total Lead (EPA 200.8)		Container Material: Plastic
Plastic		Container Size (in MI): 250 ml
HNO3		Preservative
Comments/Field Data		
Date/Time	Comments	
5/26		
5/28/2020 8:00		
5/28/20 1315		

Print Name and Company
Ernest Spencer
 Ernest Spencer
 Kunka Contracting

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of its intent to subcontract and are in agreement with this action.

SHERMAN

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	N/A
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:	SHERMAN ELEM					Pickup:	YES NO
Quote ID:	Lead Testing	PO#:				Dropoff:	C W
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material:	
Email Results:	Yes	rfilley@boces.com fhauck@boces.com ishaw@boces.com				Container Size(In MI)	
Fax Results:	Yes					Preservative	

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Type			
Ca1	3/27	600	DW	1		 <p>J 0 C 0 2 8 1</p> <p>efferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks</p>
Ca7	↓	640				
Ca0	↓	1300				

Sampled:	Print Name and Company	Date/Time	Comments
<i>[Signature]</i>		2/27/20	
<i>[Signature]</i>		2/28/20	2-28/15:25
<i>[Signature]</i>		2/28/20	15:25