



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Starbuck Elementary

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 03/13/2020
Reported: 03/31/2020

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 8, Drinking Water, J0C1044-01, Client, 03/06/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row: Method: EPA 200.8, Rv. 5.4, Lead, 0.0107, 0.015 AL, 0.0010, mg/L, 03/26/20 0959, 03/26/20 1106, LLW

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 7, Drinking Water, J0C1044-02, Client, 03/06/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row: Method: EPA 200.8, Rv. 5.4, Lead, 0.0029, 0.015 AL, 0.0010, mg/L, 03/26/20 0959, 03/26/20 1151, LLW

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 2, Drinking Water, J0C1044-03, Client, 03/06/2020 6:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row: Method: EPA 200.8, Rv. 5.4, Lead, 0.0066, 0.015 AL, 0.0010, mg/L, 03/26/20 0959, 03/26/20 1155, LLW

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 1, Drinking Water, J0C1044-04, Client, 03/06/2020 6:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row: Method: EPA 200.8, Rv. 5.4, Lead, 0.0030, 0.015 AL, 0.0010, mg/L, 03/26/20 0959, 03/26/20 1206, LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 5	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-05		<b>Collection Date:</b> 03/06/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0070	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1158	LLW

<b>Client Sample ID:</b> 15	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-06		<b>Collection Date:</b> 03/06/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0031	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1210	LLW

<b>Client Sample ID:</b> 14	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-07		<b>Collection Date:</b> 03/06/2020 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1213	LLW

<b>Client Sample ID:</b> 16	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-08		<b>Collection Date:</b> 03/06/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0016	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1217	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 12	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-09		<b>Collection Date:</b> 03/06/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0042	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1228	LLW

<b>Client Sample ID:</b> 11	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-10		<b>Collection Date:</b> 03/06/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0032	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1232	LLW

<b>Client Sample ID:</b> 17	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-11		<b>Collection Date:</b> 03/06/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0088	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1236	LLW

<b>Client Sample ID:</b> 18	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-12		<b>Collection Date:</b> 03/06/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0030	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1239	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 20a	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-13		<b>Collection Date:</b> 03/06/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0091	0.015 AL	0.0010	mg/L		03/26/20 0959	03/26/20 1243	LLW

<b>Client Sample ID:</b> 20b	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-14		<b>Collection Date:</b> 03/06/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0091	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1302	LLW

<b>Client Sample ID:</b> 21	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-15		<b>Collection Date:</b> 03/06/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0036	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1313	LLW

<b>Client Sample ID:</b> 43	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-16		<b>Collection Date:</b> 03/06/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0052	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1317	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 40	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-17		<b>Collection Date:</b> 03/06/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0035	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1320	LLW

<b>Client Sample ID:</b> 25a	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-18		<b>Collection Date:</b> 03/06/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0078	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1324	LLW

<b>Client Sample ID:</b> 28	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-19		<b>Collection Date:</b> 03/06/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0039	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1328	LLW

<b>Client Sample ID:</b> 39	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-20		<b>Collection Date:</b> 03/06/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0219	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1339	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 36	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-21		<b>Collection Date:</b> 03/06/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0034	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1343	LLW

<b>Client Sample ID:</b> 41	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-22		<b>Collection Date:</b> 03/06/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0170	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1346	LLW

<b>Client Sample ID:</b> 31	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-23		<b>Collection Date:</b> 03/06/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0061	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1350	LLW

<b>Client Sample ID:</b> 29	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-24		<b>Collection Date:</b> 03/06/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0097	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1354	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 35	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-25		<b>Collection Date:</b> 03/06/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0084	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1401	LLW

<b>Client Sample ID:</b> 34	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-26		<b>Collection Date:</b> 03/06/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1405	LLW

<b>Client Sample ID:</b> 42	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-27		<b>Collection Date:</b> 03/06/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0108	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1409	LLW

<b>Client Sample ID:</b> 4	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-28		<b>Collection Date:</b> 03/06/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0070	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1412	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 22	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-29		<b>Collection Date:</b> 03/06/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0087	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1423	LLW

<b>Client Sample ID:</b> 23	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-30		<b>Collection Date:</b> 03/06/2020 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0034	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1427	LLW

<b>Client Sample ID:</b> 27	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-31		<b>Collection Date:</b> 03/06/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1431	LLW

<b>Client Sample ID:</b> 26a	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-32		<b>Collection Date:</b> 03/06/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0043	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1435	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 47	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-33		<b>Collection Date:</b> 03/06/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0020	0.015 AL	0.0010	mg/L		03/26/20 1150	03/26/20 1438	LLW

<b>Client Sample ID:</b> 53a	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-34		<b>Collection Date:</b> 03/06/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0052	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1250	DLO

<b>Client Sample ID:</b> 51	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-35		<b>Collection Date:</b> 03/06/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1255	DLO

<b>Client Sample ID:</b> 53b	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-36		<b>Collection Date:</b> 03/06/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0016	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1257	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 48	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-37		<b>Collection Date:</b> 03/06/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0124	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1259	DLO

<b>Client Sample ID:</b> 52b	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-38		<b>Collection Date:</b> 03/06/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0015	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1301	DLO

<b>Client Sample ID:</b> 46	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-39		<b>Collection Date:</b> 03/06/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0032	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1303	DLO

<b>Client Sample ID:</b> 49	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-40		<b>Collection Date:</b> 03/06/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0102	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1308	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 52a	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-41		<b>Collection Date:</b> 03/06/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0048	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1310	DLO

<b>Client Sample ID:</b> 50	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-42		<b>Collection Date:</b> 03/06/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0102	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1312	DLO

<b>Client Sample ID:</b> 26b	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-43		<b>Collection Date:</b> 03/06/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0081	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1314	DLO

<b>Client Sample ID:</b> 32	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-44		<b>Collection Date:</b> 03/06/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0097	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1315	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

<b>Client Sample ID:</b> 37	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-45		<b>Collection Date:</b> 03/06/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1319	DLO

<b>Client Sample ID:</b> 44	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-46		<b>Collection Date:</b> 03/06/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0155	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1321	DLO

<b>Client Sample ID:</b> 45	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-47		<b>Collection Date:</b> 03/06/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0094	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1323	DLO

<b>Client Sample ID:</b> 25b	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J0C1044-48		<b>Collection Date:</b> 03/06/2020 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0164	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1325	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C1044

Client Sample ID: 33	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 03/06/2020 6:48
Lab Sample ID: J0C1044-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<b>0.0167</b>	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1330	DLO

Client Sample ID: 38	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 03/06/2020 6:51
Lab Sample ID: J0C1044-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0072	0.015 AL	0.0010	mg/L		03/26/20 1225	03/26/20 1332	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 03/31/2020 13:42

STARBUCK ELEM

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	STARBUCK ELEM		
Quote ID:	Lead Testing	PO#	
Ruth TAT Bur. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfliley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information		
Description/Location	Date	Time
8	3/6/20	6:39
7		6:35
2		6:36
1		6:56
5		6:38
15		6:30
14		6:18
16		6:32
12		6:33
11		6:35
17		6:33
18		6:33
20A		6:28
20B		6:28
21		6:25
43		6:55
40		6:57
25A		6:43
28		6:50
39		6:52

Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Type	DW				
Plastic		1			
250 ml					
HINO3					
Total Lead (EPA 200.8)					


  

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	11A
Cooler seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO

Container Material	
Container size (in MI)	
Preservative	



J 0 C 1 0 4 4

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks

Sampled:	Received:	Received:	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/6/20	
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/13/2020 8:55	1300
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	3/17/20 1300	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

*Starruck Elem*

<b>Client Information</b>		<b>Billing/Invoice:</b>	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>STARRUCK ELEM</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Type	
31a	3/6/20	6:55	DW	
41		6:57		
31		6:49		
29		6:50		
35		6:55		
34		6:55		
42		6:57		
4		6:38		
22		6:40		
23		6:42		
27		6:45		
26A		6:45		
47		7:00		
53A		7:02		
51		7:02		
53B		7:05		
48		7:06		
52B		7:00		
40		7:00		
49		7:02		

<b>Receiving Info (Lab Use Only)</b>	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	N/A
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container Size (in MI)	
Preservative	

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks



Number of Containers for Analysis Requested	Comments/Field Data
1	

Print Name and Company  
*Ernest Spore*  
*Vaulta Conwin*

Sampled: *3/10/20*  
 Received: *3/13/2020 P. 4:45*  
 Received: *3/17/2020 13:50*

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document, you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

