



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0B1398

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Wiley Intermediate

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 02/28/2020
 Reported: 03/30/2020

Analytical Testing Parameters

Client Sample ID: 49								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0B1398-01					Collection Date: 02/27/2020 6:55			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0056	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1515	DLO

Client Sample ID: 40c								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0B1398-02					Collection Date: 02/27/2020 6:54			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0063	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1518	DLO

Client Sample ID: 86								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0B1398-03					Collection Date: 02/27/2020 6:54			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.183	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1520	DLO

Client Sample ID: 30a								
Sample Matrix: Drinking Water					Collected By: Client			
Lab Sample ID: J0B1398-04					Collection Date: 02/27/2020 6:43			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0117	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1522	DLO

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-05		Collection Date: 02/27/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0264	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1524	DLO

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-06		Collection Date: 02/27/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1529	DLO

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-07		Collection Date: 02/27/2020 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0062	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1531	DLO

Client Sample ID: 27a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-08		Collection Date: 02/27/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1533	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 56a	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:00
Lab Sample ID: J0B1398-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1535	DLO

Client Sample ID: 28b	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:40
Lab Sample ID: J0B1398-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0033	0.015 AL	0.0010	mg/L		03/17/20 1034	03/17/20 1536	DLO

Client Sample ID: 6	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:30
Lab Sample ID: J0B1398-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0474	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1630	DLO

Client Sample ID: 58c	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:02
Lab Sample ID: J0B1398-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0070	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1635	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-13		Collection Date: 02/27/2020 6:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1637	DLO

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-14		Collection Date: 02/27/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0050	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1639	DLO

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-15		Collection Date: 02/27/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0153	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1641	DLO

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-16		Collection Date: 02/27/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0046	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1642	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 30b	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:43
Lab Sample ID: J0B1398-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0118	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1648	DLO

Client Sample ID: 10	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:36
Lab Sample ID: J0B1398-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0117	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1650	DLO

Client Sample ID: 28a	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:40
Lab Sample ID: J0B1398-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0090	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1652	DLO

Client Sample ID: 32	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:50
Lab Sample ID: J0B1398-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.717	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1653	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 48a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-21		Collection Date: 02/27/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1655	DLO

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-22		Collection Date: 02/27/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0109	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1659	DLO

Client Sample ID: 14	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-23		Collection Date: 02/27/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0207	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1701	DLO

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-24		Collection Date: 02/27/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0036	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1703	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 38a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-25		Collection Date: 02/27/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0034	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1704	DLO

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-26		Collection Date: 02/27/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0120	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1710	DLO

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-27		Collection Date: 02/27/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0147	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1712	DLO

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-28		Collection Date: 02/27/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0103	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1714	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-29		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0091	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1715	DLO

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-30		Collection Date: 02/27/2020 9:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.62	0.015 AL	0.0010	mg/L		03/17/20 1542	03/17/20 1717	DLO

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-31		Collection Date: 02/27/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0021	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1726	DLO

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-32		Collection Date: 02/27/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0020	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1732	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-33		Collection Date: 02/27/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0138	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1734	DLO

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-34		Collection Date: 02/27/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.209	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1736	DLO

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-35		Collection Date: 02/27/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0066	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1737	DLO

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-36		Collection Date: 02/27/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0068	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1739	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 38b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-37		Collection Date: 02/27/2020 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0013	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1745	DLO

Client Sample ID: 40a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-38		Collection Date: 02/27/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0054	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1747	DLO

Client Sample ID: 38c	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-39		Collection Date: 02/27/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0058	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1748	DLO

Client Sample ID: 26a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-40		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1750	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-41		Collection Date: 02/27/2020 6:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0190	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1752	DLO

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-42		Collection Date: 02/27/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0039	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1756	DLO

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-43		Collection Date: 02/27/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0083	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1758	DLO

Client Sample ID: 40b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-44		Collection Date: 02/27/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1759	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-45		Collection Date: 02/27/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0062	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1801	DLO

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-46		Collection Date: 02/27/2020 6:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0094	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1807	DLO

Client Sample ID: 87	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-47		Collection Date: 02/27/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.204	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1809	DLO

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-48		Collection Date: 02/27/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0140	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1810	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 31	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-49		Collection Date: 02/27/2020 6:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0281	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1812	DLO

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-50		Collection Date: 02/27/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0026	0.015 AL	0.0010	mg/L		03/17/20 1544	03/17/20 1814	DLO

Client Sample ID: 26b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-51		Collection Date: 02/27/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1823	DLO

Client Sample ID: 58a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-52		Collection Date: 02/27/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0069	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1829	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 56b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-53		Collection Date: 02/27/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1831	DLO

Client Sample ID: 41b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-54		Collection Date: 02/27/2020 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1832	DLO

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-55		Collection Date: 02/27/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0086	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1834	DLO

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-56		Collection Date: 02/27/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0170	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1836	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-57		Collection Date: 02/27/2020 6:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0045	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1842	DLO

Client Sample ID: 82a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-58		Collection Date: 02/27/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0057	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1843	DLO

Client Sample ID: 48b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-59		Collection Date: 02/27/2020 6:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0022	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1845	DLO

Client Sample ID: 27b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-60		Collection Date: 02/27/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1847	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 41a	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:47
Lab Sample ID: J0B1398-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1849	DLO

Client Sample ID: 58b	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:22
Lab Sample ID: J0B1398-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1853	DLO

Client Sample ID: 57c	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:04
Lab Sample ID: J0B1398-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0066	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1854	DLO

Client Sample ID: 35	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 6:49
Lab Sample ID: J0B1398-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0114	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1856	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-65		Collection Date: 02/27/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1858	DLO

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-66		Collection Date: 02/27/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0043	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1904	DLO

Client Sample ID: 83a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-67		Collection Date: 02/27/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0010	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1905	DLO

Client Sample ID: 81a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-68		Collection Date: 02/27/2020 7:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0095	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1907	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-69		Collection Date: 02/27/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0054	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1909	DLO

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-70		Collection Date: 02/27/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.155	0.015 AL	0.0010	mg/L		03/17/20 1545	03/17/20 1911	DLO

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-71		Collection Date: 02/27/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0458	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1920	DLO

Client Sample ID: 60a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-72		Collection Date: 02/27/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0048	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1926	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 57a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-73		Collection Date: 02/27/2020 7:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0057	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1927	DLO

Client Sample ID: 61a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-74		Collection Date: 02/27/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0024	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1929	DLO

Client Sample ID: 66c	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-75		Collection Date: 02/27/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0061	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1931	DLO

Client Sample ID: 66b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-76		Collection Date: 02/27/2020 7:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1933	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 57b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-77		Collection Date: 02/27/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1938	DLO

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-78		Collection Date: 02/27/2020 6:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0054	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1940	DLO

Client Sample ID: 60b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-79		Collection Date: 02/27/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0018	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1942	DLO

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-80		Collection Date: 02/27/2020 7:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0068	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1944	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 62a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-81		Collection Date: 02/27/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0035	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1946	DLO

Client Sample ID: 65c	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-82		Collection Date: 02/27/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0081	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1949	DLO

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-83		Collection Date: 02/27/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0068	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1951	DLO

Client Sample ID: 82b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-84		Collection Date: 02/27/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0025	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1953	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-85		Collection Date: 02/27/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0176	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 1955	DLO

Client Sample ID: 75	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-86		Collection Date: 02/27/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0049	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 2001	DLO

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-87		Collection Date: 02/27/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0051	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 2002	DLO

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-88		Collection Date: 02/27/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0413	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 2004	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 65a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-89		Collection Date: 02/27/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0107	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 2006	DLO

Client Sample ID: 62b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-90		Collection Date: 02/27/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0033	0.015 AL	0.0010	mg/L		03/17/20 1546	03/17/20 2008	DLO

Client Sample ID: 81b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-91		Collection Date: 02/27/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0015	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2017	DLO

Client Sample ID: 77	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-92		Collection Date: 02/27/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.221	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2023	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-93		Collection Date: 02/27/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0144	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2024	DLO

Client Sample ID: 60c	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-94		Collection Date: 02/27/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0066	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2026	DLO

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-95		Collection Date: 02/27/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.350	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2028	DLO

Client Sample ID: 65b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-96		Collection Date: 02/27/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0017	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2030	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 82c	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-97		Collection Date: 02/27/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0068	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2035	DLO

Client Sample ID: 71	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-98		Collection Date: 02/27/2020 7:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0032	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2037	DLO

Client Sample ID: 61b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-99		Collection Date: 02/27/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2039	DLO

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AA		Collection Date: 02/27/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0057	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2041	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 74a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AB		Collection Date: 02/27/2020 7:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2043	DLO

Client Sample ID: 83b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AC		Collection Date: 02/27/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2046	DLO

Client Sample ID: 62b	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AD		Collection Date: 02/27/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0012	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2048	DLO

Client Sample ID: 79	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AE		Collection Date: 02/27/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.129	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2050	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 66a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AF		Collection Date: 02/27/2020 7:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0059	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2052	DLO

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AG		Collection Date: 02/27/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0053	0.015 AL	0.0010	mg/L		03/20/20 0858	03/20/20 1036	LLW

Client Sample ID: 62a	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AH		Collection Date: 02/27/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0014	0.015 AL	0.0010	mg/L		03/20/20 0858	03/20/20 1032	LLW

Client Sample ID: 78	Sample Matrix: Drinking Water	Collected By: Client
Lab Sample ID: J0B1398-AI		Collection Date: 02/27/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0290	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2101	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0B1398

Client Sample ID: 74b	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:14
Lab Sample ID: J0B1398-AJ	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2103	DLO

Client Sample ID: 61c	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 02/27/2020 7:06
Lab Sample ID: J0B1398-AK	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0044	0.015 AL	0.0010	mg/L		03/17/20 1548	03/17/20 2105	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 03/30/2020 11:21

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00835


Samples must be returned on ice
 MNY Workorder #

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: WILLEY WATERWORKS
 Quote ID: Lead Testing
 Rush TAT Bus. Days: 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 Total Lead (EPA 200.8)

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Container Material
 Plastic
Container Size (in ml)
 250 ml
Preservative
 HNO3

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Type			
49	3/27	6:55	DW	1		 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks
490c		6:54				
86		6:54				
30A		6:43				
22		6:16				
15		6:26				
3		6:34				
27A		6:46				
56A		7:00				
28B		6:40				
6		6:30				
58C		7:02				
20		6:12				
18		6:20				
13		6:22				
16		6:09				
30B		6:13				
10		6:36				
28A		6:46				
32		6:50				

Print Name and Company
 Sampled: [Signature]
 Received: [Signature]
 Received: [Signature]

Date/Time
 3/27/2020 8:00
 3/24/2020 8:00
 3/24/2020 8:00

Comments
 [Handwritten notes]

Microbac Laboratories (NY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10785, EPA #NY00835

Samples must be returned on ice
 MNY Workorder #

Wiley

Client Information Name: Jeff/Lew Boces Address: 20104 NYS Route 3 Contact: Health/Safety Dept. Phone: 315-779-7000 Project: <i>WILEY INTERMEDIATE</i> Quote ID: <i>WILEY</i> PO#: Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req.: Carbon Copy: Yes Email Results: Yes Email: rfilley@boces.com fhauck@boces.com ishaw@boces.com Fax Results: Yes		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only) Ice: YES NO Cooler: YES NO Sample Temp: <i>N/A</i> Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material: Container Size (in MI): Preservative:	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Matrix Type				
48 A	2/27	6:58	DW				
7		6:57					
14		6:26					
21		6:14					
38A		6:57					
4		6:37					
24		6:15					
8		6:35					
33		6:45					
30		9:11					
37		6:32					
5		6:30					
54		7:00					
35		6:39					
17		6:20					
44		6:50					
38B		6:42					
40A		6:53					
38C		6:48					
26A		6:45					
Total Lead (EPA 200.8) Plastic 250 ml HNO3 1				Job 1398 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks			
Sampled: <i>[Signature]</i>		Date/Time: 2/27 12/3		Comments:			
Received: <i>[Signature]</i>		Date/Time: 2/28/2020 8:00		Comments:			
Received: <i>[Signature]</i>		Date/Time: 1/28/2020 13:5		Comments:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10786, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: WILEY INTERADDIATE
 Quote ID: WILEY Lead Testing
 Rush TAT Bus. Days: 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 Billing To: Total Lead (EPA 200.8)
 Billing From: Plastic
 Billing To: 250 ml
 Billing From: HNO3

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Sample Information		Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested
34	2/27	6:51	DW	DW	1
42		6:50			
53		7:01			
40B		6:53			
44		6:52			
9		6:36			
87		6:28			
2		6:31			
31		6:49			
23		6:16			
26B		6:43			
S8A		7:02			
S6B		7:00			
41B		6:47			
36		6:45			
47		6:53			
57		6:57			
82A		7:10			
48B		6:49			
27B		6:46			

JOB 1398
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Print Name and Company
 Sampled: Ernest Sperry
 Received: Ernest Sperry
 Received: Ernest Sperry

Date/Time: 2/27
 2/28/2020 2:00 PM
 2/28/2020 1:56 PM

Comments:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
Cortland NY 13045
Phone: (607)753-3403 Fax: (607)753-3415
NY #10795, EPA #NY00935

Samples must be returned on ice
MNY Workorder #


Wiley

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	<i>WILEY WATER</i>		
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information			
Description/Location	Date	Time	Matrix Type
41A	2/27	6:47	DW
S8B		7:22	
S7C		7:04	
35		6:49	
11		6:21	
45		6:58	
83A		7:07	
61A		7:04	
416		6:52	
69		7:14	
68		7:18	
60A		7:07	
S7A		7:03	
61A		7:06	
66C		7:13	
66B		7:20	
S7B		7:18	
29		6:42	
60B		7:07	
607		7:19	

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	<i>N/A</i>
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO

Analysis Requested	
Number of Containers for Analysis Requested	Comments/Field Data
Total Lead (EPA 200.8)	
Plastic	
250 ml	
HNO3	
1	



J 0 B 1 3 9 8

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
PM: Shannon Weeks

Sampled:	Print Name and Company	Date/Time	Comments
<i>[Signature]</i>	<i>[Signature]</i>	2/27	
Received:	<i>[Signature]</i>	7/28/2020	2007/13-120
Received:	<i>[Signature]</i>	1/28/2020	13-120

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: *wiley INTRIC*
 Quote ID: Lead Testing
 PO#:
 Date Req:
 Rush TAT Bus. Days: < 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes
 Email: rfilley@boces.com, jhauck@boces.com, lshaw@boces.com
 Billing/Invoice:
 Total Lead (EPA 200.8)

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Type				
602A	2/6	714	DW				
605C		715					
50		659					
822B		710					
55		702					
75		715					
76		712					
72		713					
605A		710					
602B		714					
81B		712					
77		714					
70		710					
600C		707					
52		658					
605B		715					
822C		710					
71		717					
601B		706					
73		712					

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks



Receiving Info (Lab Use Only)
 Ices: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Container Material
 Container size (in MI)
 Preservative

Print Name and Company
 Received: *Shannon Weeks*
 Date/Time: 2/28/2020 2:00 PM
 Comments: *2/28/2020 2:00 PM 3125*

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: wiley / MTR
 Quote ID: Lead Testing
 Rush TAT Bus. Days: < 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 PO#: _____
 Date Req: _____

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: N/A
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO

Container Material: Plastic
 Container Size (in MI): 250 ml
 Preservative: HNO3

Sample Information		Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Matrix Type	
74A		7:10	DW	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE PM: Shannon Weeks
83B		7:07		
62B		7:05		
79		7:12		
66A		7:20		
85		7:15		
62A		7:05		
78		7:12		
74B		7:14		
61C		7:00		
1				1
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Print Name and Company
 Sampled: _____
 Received: _____
 Received: _____

Date/Time: 3/27
 3/26/2020 8:00 / 13:25
 2/20/2020 13:25

Comments: _____

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.